

Town of Ridgefield
Office of the Purchasing Manager

Addendum Number 2

Bid Number 25-01

Request for Quotes

Scotts Ridge School Fence

To All Bidders:

The following questions were received relating to this RFQ;

- *The fence we are installing, is it regular extruded or fuse bonded mesh? // The specifications state that the gauge of the mesh refers to the wire BEFORE coating. Therefore, the new chain link mesh is to be fused, correct? **Regular extruded.***
- *We are required to submit our proposal on a company letterhead, correct? **Proposals should be submitted on company letterhead.***
- *who is responsible for the clearing of all overgrowth (if any) to facilitate the installation of the new chain link mesh? **The Town will be responsible for clearing brush/overgrowth as needed to facilitate installation.***